

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-0026:240 Page 1 of 1

CATEGORY: Misc. Devices/Control Unit Accessories

LISTEE: Simplex, 100 Simplex Drive, Westminster, MA 01441-0001
Contact: Paul Mattern (978) 731-8542 *FAX (978) 731-8881

DESIGN: Model RSx-GR-GP4 fire fighter smoke control station. Suffix -x is indicating A, B, C, D, E or G. This unit is intended to be interconnected with Simplex's Model 4100/4120 fire alarm control unit (CSFM Listing No. 7165-0026:160) to provide remote annunciation of various signals. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as smoke control panel for use with listee's separately listed compatible Model 4100/4120 fire alarm control units. For indoor use only.

*Rev. 05-13-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 17, 2004

*Listing Expires **June 30, 2005***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager